



Product Service

CERTIFICATE

No. Z2 112919 0002 Rev. 01

Holder of Certificate: **Nuuko Power Co.,Ltd**
No. 16 Building, Xiangcheng Road
Feidong Economic Development Zone
231600 Hefei City, Anhui Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062357901-01

Valid until: 2030-03-25

Date, 2025-03-31

(Zhulin Zhang)

CERTIFICATE

No. Z2 112919 0002 Rev. 01

Model(s):

NKMxxxN-132BDG12 (xxx=670-725 in steps of 5W)
NKMxxxN-120BDG12 (xxx=615-660 in steps of 5W)
NKMxxxN-108BDG12 (xxx=550-590 in steps of 5W)
NKMxxxN-156BDM10 (xxx=605-655 in steps of 5W)
NKMxxxN-144BDM10 (xxx=560-605 in steps of 5W)
NKMxxxN-132BDM10 (xxx=515-555 in steps of 5W)
NKMxxxN-120BDM10 (xxx=465-500 in steps of 5W)
NKMxxxN-108BDM10 (xxx=420-450 in steps of 5W)
NKMxxxN-132BDR12 (xxx=600-635 in steps of 5W)
NKMxxxN-120BDR12 (xxx=545-575 in steps of 5W)
NKMxxxN-108BDR12 (xxx=490-520 in steps of 5W)
NKMxxxN-96BDR12 (xxx=435-460 in steps of 5W)
xxx is standing for rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co.,Ltd. B Area on 1/F., Building 12, C Area on 4/F., and A Area on 1/F., Building 10, No. 8, Lanxiang Road, West Taihu Science and Technology Industrial Park, Changzhou Jiangsu, China
Construction:	Framed, with Junction box, cable and connectors.
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2023
IEC 61730-2:2023